

# **ARABIAN ACRES METROPOLITAN DISTRICT**

**MONTHLY OPERATIONS REPORT for period: Jan. 12, 2017 to February 10, 2017**

**Submitted by: Lynn Willow, Operator/O.R.C.**

## **TOTAL WELL PRODUCTION**

**Control Building –A: 329,687 gallons**

**Control Building – B: 101,310 gallons**

## **TOTAL PURCHASED WATER**

**Trucked – 0 loads**

**(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)**

## **OPERATIONS & MAINTENANCE ISSUES**

- Bac-T samples for the month have been taken and are negative.
- Ordered a Kop kit for chemical pump. It is a rebuilt kit for pumps \$109.30
- Requesting the AAMD board to approve the purchase of one chem. Pump as back up. We Usually get a pump every two to three years.
- As mentioned last month that I am looking into the coast of a Tank circulator to eliminate the Buildup of ice in the storage tank. They are in the range of \$9,000.00 to \$10,000.00. I have met with two tank companies and got quotes from both and have forward to Judy.
- System is working well at this time with no leaks.

## **OTHER BUSINESS:**

Winter is here! All residents should check their home's for proper piping insulation and leave your cabinet doors open under your sinks at night to prevent freezing.

Remember, all customers get one free water service turn on and turn off for the year.